

Strojírenský zkušební ústav, s.p., Brno, Česká republika Engineering Test Institute, Public Enterprise, Brno, Czech Republic

TEST CERTIFICATE

Number

O-39-01231-15

HOTJET CZ s.r.o.

Průmyslová 966/21 747 23 Bolatice, ČR

IČ: 27764290

Product Air/Water Heat Pump - Monobloc

Type designation /

Trade mark

Manufacturer

Indoor units: ---

Outdoor units - HOTJET: 10 ONE2, 15 ONE2, 20 ONE2, 25 ONE2

ČSN EN 14511-1:2014 to ČSN EN 14511-4:2014, **Test Procedure**

ČSN EN 14825:2014, ČSN EN 12102:2014; EHPA Testing regulation - Testing of Air/Water Heat Pumps, version 2.2

Test Reports: 39-10677/T/2 and 39-10677/H/2 of 2015-11-11; Basis of certificate

Test Report 39-10418/H/2 of 2015-01-06;

Technical documents submitted by HOTJET CZ s.r.o.

"A" = average / "C" = colder / "W" = warmer Reference heating season

- reference design conditions for heating T_{designh} = -10 °C /-22 °C /+2 °C -

Temperature application

HIGH

reference water temperature 55°C –

Conditions specification:

Compressor speed control

ON/OFF

Rated liquid flow rate -Outdoor heat exchanger

Outlet water temperature -Indoor heat exchange

Variable

Rated liquid flow rate -Indoor heat exchanger

Variable

Heating only / Reversible

Reversible

Registered Test Centre

heat pump association

O-39-01231-15, page 1 (2)

Strojírenský zkušební ústav, s.p., Hudoova 424/56b, 621 00 Brno, Česká republika Engineering Test Institute, public enterprise, Hudcova 424/56b, 621 00 Brno, Czech Republic



Results:

"A" = average / "C" = colder / "W" = warmer

– reference design conditions for heating $T_{designh}$ = -10 °C / -22 °C / +2 °C –

			HOTJET			
Model name*:			10 ONE2	15 ONE2	20 ONE2	25 ONE2
			(Tested)	(Not tested)	(Not tested)	(Not tested)
	High	temper	ature application	(reference water ter	mperature 55 °C)	
Full load heating	P _{designh} [kW]	Α	9.28	11.3	15.6	21.4
		С	10.39	12.3	17.5	26.0
		W	10.20 (Not tested)	11.9	17.0	24.8
Bivalent temperature	T _{bivalent}	Α	-7	-7	-7	-7
		С	-10	-10	-10	-10
		W	2	2	2	2
Seasonal coefficient of performance	SCOP [-]	Α	3.01	2.94	3.23	3.38
		С	2.66 (Not tested)	2.70	2.86	2.91
		W	3.63 (Not tested)	3.65	3.86	3.91
		Sour	nd power level at	A7/W55* (accurac	cy class 2)	
L _W (A)	[dB(A)]		67.7	68.5	69.5	71.5 (Tested)
Outdoor unit			± 1.5	± 1.5	± 1.5	± 1.5

(*) Comment to abbreviated marking: eg. A7/W55

A" air, "7" inlet temperature (dry temperature) in °C "W" water, "55" outlet temperature in °C. (Tested) This test sample/condition was tested in the Testing Laboratory. (Not tested) The technical data were declared by the Manufacturer according to the model range specifications and were not tested by the Testing Laboratory.

The Engineering Test Institute, Public Enterprise, approves with this test certificate that testing of the product in question was performed with the results as stated above. The Engineering Test Institute, Public Enterprise, is accredited testing laboratory No. 1045.1.

Brno, 2015-11-11

Milan Holomek

Head of Heat and Ecological Equipment Testing Laboratory Manager

- END OF TEST CERTIFICATE-

O-39-01231-15, page 2 (2)

Strojírenský zkušební ústav, s.p., Hudcova 424/56b, 621 00 Brno, Česká republika Engineering Test Institute, public enterprise, Hudcova 424/56b, 621 00 Brno, Czech Republic